

## ADULT FAMILY HOME FIRE SAFETY GUIDE

This guide can be used to assist the applicant, licensee and licensing specialist to determine compliance with the fire safety requirements of HSS 88. This form is not mandatory.

Name of Home

Address

City-State-Zip

Licensee Name

County

Name - Person Completing This Form

Date Completed

YES	NO	FIRE SAFETY
<input type="checkbox"/>	<input type="checkbox"/>	1. Is the home free from hazards and kept uncluttered and free of dangerous substances? [HSS 88.05(3)(b)]
<input type="checkbox"/>	<input type="checkbox"/>	2. Does the home have at least two (2) means of exiting which provide unobstructed travel to the outside? [HSS 88.05(4)(c)1.]
<input type="checkbox"/>	<input type="checkbox"/>	3. Does the home have exits ramped to grade with a hard surfaced pathway with handrails if a resident is not able to walk at all or able to walk only with difficulty or only with the assistance of crutches, a cane, or walker or is unable to easily negotiate stairs without assistance? [HSS 88.05(2)(a) and (a)1.]
<input type="checkbox"/>	<input type="checkbox"/>	4. Does the licensee have a written plan for the immediate and safe evacuation of all occupants of the home in the event of a fire? [HSS 88.05(4)(d)1.]
<input type="checkbox"/>	<input type="checkbox"/>	5. Does the fire evacuation plan identify an external meeting place? [HSS 88.05(4)(d)1]
<input type="checkbox"/>	<input type="checkbox"/>	6. Does the licensee review the fire safety evacuation plan with each new resident immediately following placement? [HSS 88.05(4)(d)2a.]
<input type="checkbox"/>	<input type="checkbox"/>	7. Does the licensee conduct semi-annual fire drills with all household members with written documentation of the date and evacuation time for each drill maintained by the home? [HSS 88.05(4)(d)2c.]
<input type="checkbox"/>	<input type="checkbox"/>	8. Is the licensee or service provider in the home at all times when a resident who is incapable of self evacuation is present in the home? [HSS 88.05(4)(f)]
<input type="checkbox"/>	<input type="checkbox"/>	9. Does the home have the telephone number for the fire department located on or near each telephone? [HSS 88.05(5)]
<input type="checkbox"/>	<input type="checkbox"/>	10. Are the residents able to easily enter and exit the home? [HSS 88.05(2)]
<input type="checkbox"/>	<input type="checkbox"/>	11. Does any resident who is unable to easily negotiate stairs without assistance have his or her bedroom, toilet and bathing facilities and all common living areas on the first floor? [HSS 88.05(2)(d)]
<input type="checkbox"/>	<input type="checkbox"/>	12. If any resident is not able to walk at all or able to walk only with difficulty, or only with the assistance of crutches, a cane, or a walker, do the exit and interior doors have a clear opening of at least 32 inches? [HSS 88.05(2)(a)2.]
<input type="checkbox"/>	<input type="checkbox"/>	13. If there is any resident in the home who has either manual strength or dexterity limitations, does the home have levered handles on all doors normally used by that resident if these can be replaced and if replacement is readily achievable? [HSS 88.05(2)(c)]
<input type="checkbox"/>	<input type="checkbox"/>	14. Does the home electrical system meet local building codes? [HSS 88.05(3)(c)]
<input type="checkbox"/>	<input type="checkbox"/>	15. Is there a condition or occurrence relating to the operation of the home that directly threatens the safety of a resident? [HSS 88.03(6)]
<input type="checkbox"/>	<input type="checkbox"/>	16. Has the oil furnace been inspected and serviced every 2 years by a heating contractor? [HSS 88.05(3)(e)2a.]
<input type="checkbox"/>	<input type="checkbox"/>	17. Has the gas furnace been inspected and serviced every 3 years by a heating contractor? [HSS 88.05(3)(e)2b.]
<input type="checkbox"/>	<input type="checkbox"/>	18. Has the chimney been visually inspected by the inspector who inspected the gas or oil furnace? [HSS 88.05(3)(e)2c.]

YES	NO	FIRE SAFETY (continued)
<input type="checkbox"/>	<input type="checkbox"/>	19. If the home has a wood burning stove or fireplace is there a flue separate from the one used by a gas or oil furnace? [HSS 88.05(3)(e)2d.]
<input type="checkbox"/>	<input type="checkbox"/>	20. If "yes" to number 19, has the flue been cleaned as often as necessary but not less than 2 times during each heating season? If this wood burning stove or fireplace is used no more than four days each month of the heating season, has the flue been cleaned at least during each heating season? [HSS 88.05(3)(e)2d.]
<input type="checkbox"/>	<input type="checkbox"/>	21. Has the licensee evaluated the new resident using the form produced by the department, DSL-2372 Resident Evacuation Assessment, to determine whether the resident is able to evacuate the home without any help within 2 minutes? [HSS 88.05(4)(d)2a.]
<input type="checkbox"/>	<input type="checkbox"/>	22. Has the licensee evaluated each resident annually for evacuation time using the department's form, DSL-2373 Resident Evacuation Assessment? [HSS 88.05(4)(d)2b.]
<input type="checkbox"/>	<input type="checkbox"/>	23. Has the licensee made all service providers who work on the premises aware of each resident having an evacuation time of more than 2 minutes? [HSS 88.05(4)9c)2b.]
<input type="checkbox"/>	<input type="checkbox"/>	24. If there was a fire in the home, which required the assistance of the fire department, did the licensee inform the licensing agency within 72 hours of the occurrence? [HSS 88.05(4)(e)]
<input type="checkbox"/>	<input type="checkbox"/>	25. Has the clothes dryer(s) in the home been properly vented in accordance with manufacturers' recommendations?
YES	NO	SMOKE DETECTION SYSTEM
<input type="checkbox"/>	<input type="checkbox"/>	26. Does the home have one or more single station, battery operated, electrically interconnected or radio signal emitting smoke detectors on each floor level? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	27. Is there a smoke detector located in each habitable room, except the kitchen and bathroom? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	28. Is there a smoke detector at the head of each open stairway? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	29. Is there a smoke detector at the door leading to every enclosed stairway? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	30. Is there a smoke detector on the ceiling of the living room or family room? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	31. Is there a smoke detector on the ceiling of every sleeping room? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	32. Is there a smoke detector in the basement? [HSS 88.05(4)(b)1.]
<input type="checkbox"/>	<input type="checkbox"/>	33. Has the licensee maintained each required smoke detector in working condition? [HSS 88.05(4)(b)2.]
<input type="checkbox"/>	<input type="checkbox"/>	34. Has the licensee documented that each smoke detector was tested monthly to make sure it is operating? If a unit is found to be not operating, the licensee is to immediately replace the battery or have the unit repaired or replaced. [HSS 88.05(4)(b)2.]
YES	NO	FIRE EXTINGUISHER
<input type="checkbox"/>	<input type="checkbox"/>	35. Is there a fire extinguisher on each floor? [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	36. Does each fire extinguisher have a minimum 2A, 10B – C rating? [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	37. Is each fire extinguisher mounted? [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	38. Is there a fire extinguisher at the head of each stairway? [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	39. Is there a fire extinguisher located in or near the kitchen? A single fire extinguisher in close proximity to the kitchen and the head of a stairway may be used to meet the requirement for an extinguisher at each location. [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	40. Is the fire extinguisher maintained in readily usable condition? [HSS 88.05(4)(a)]
<input type="checkbox"/>	<input type="checkbox"/>	41. Is the fire extinguisher inspected annually by an authorized dealer or the local fire department with an attached tag showing the date of the last dealer or fire department inspection? [HSS 88.05(f)(a)]